M3-8 TYPICAL



SWITCH DISTRIBUTION PANEL
120/240V 3Ø,4W

Meter#	Current Transformer#	BRK. AMP.	PHASE	Breaker#		PHASE	PHASE	BRK. AMP.	Current Transformer#	Meter#
MTR#01	01	200A	A	01	2-POLE	02	A	200A	03	MTR#02
	02		B	03		04	B		04	
MTR#03	05	200A	C	05	2-POLE	06	C	200A	07	MTR#04
	06		A	07		08	A		08	
MTR#05	09	200A	B	09	2-POLE	10	B	200A	11	MTR#06
	10		C	11		12	C		12	
MTR#07	13	200A	A	13	2-POLE	14	A	200A	15	MTR#08
	14		B	15		16	B		16	

TYPICAL
FOR
ALL CONNECTORS

VOL. REF.	15A		A	3-POLE				
			B					
			C					

NEUTRAL

WARNING: METERING PANEL HAS BEEN PHASED ACCORDINGLY.
DO NOT CHANGE ASSIGNED DISTRIBUTION.

SDP AND EMP DESIGNATION

SUITE NO.		METER NO.	SUITE NO.		METER NO.
	IS METERED BY →	METER#01		IS METERED BY →	METER#02
	IS METERED BY →	METER#03		IS METERED BY →	METER#04
	IS METERED BY →	METER#05		IS METERED BY →	METER#06
	IS METERED BY →	METER#07		IS METERED BY →	METER#08

N.B.: PLEASE COMPLETE THE SHOP DRAWING WITH THE APPROPRIATE SUITE INDENTIFICATION.

SDP : Switch Distribution Panel EMP: Electronic Metering Panel

CT: Current Transformer

Intellimeter Canada Architectual & Engineering Services

Intellimeter CANADA INC.
Architectual & Engineering services
1125 Squires Beach Road Pickering,Ontario L1W 3T9
Phone:(905) 839-9199 Fax:(905) 839-9198

Project Name:	Distributor:	Engineer:	P.O.#	Contractor:	Date:	Rev.:	Project#:	Drawing#:	Drawn By:	Drawing:
									Hossein Pakbin	